

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. Havens Street
Kokomo, IN 56901-3188

10/30/2000

Job Number: 00.05585
Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to TestAmerica, Inc. Indianapolis Division for analysis:

Project Description: WASTEWATER ANALYSIS

Sample Number	Sample Description	Date Taken	Time Taken	Date Received
278189	MONTHLY SAMPLE	10/12/2000	15:30	10/13/2000

TestAmerica, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

TestAmerica Incorporated-Indianapolis Division is in compliance with the National Environmental Laboratory Accreditation Program (NELAP) Standards.

Reproduction of this analytical report is permitted only in its entirety.

MIL0005525

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. Havens Street
Kokomo, IN 56901-3188

10/30/2000

Job No.: 00.05585
Page 2 of 3

Date Received: 10/13/2000
Job Description: WASTEWATER ANALYSIS

Sample Number / Sample I.D.			Sample Date/	Analyst		Reporting
Parameters	Wet Wt. Result	Flag	Units	Date & Time Analyzed	Method	Limit
278189	MONTHLY SAMPLE		10/12/2000 15:30			
CBOD - Five Day	>10		mg/L	rlm 10/18/2000 10:10	EPA 405.1	<5.
CBOD - Five Day (PREP)	Complete			rlm 10/13/2000 13:50	EPA 405.1	Complete
COD	700	dlx10	mg/L	aka 10/17/2000	EPA 410.4	<10.
Nitrogen, Ammonia Dist.	<0.30		mg/L	DT 10/26/2000	EPA 350.1	<0.30
Solids, Suspended	96		mg/L	rlm 10/16/2000 12:30	EPA 160.2	<5.
Distillation, Ammonia	Complete			DT 10/25/2000		Complete
Molybdenum, ICP	0.028		mg/L	tyj 10/21/2000 23:54	EPA 200.7	<0.020
Zinc, ICP	0.053		mg/L	tyj 10/21/2000 23:54	EPA 200.7	<0.020

KEY TO ABBREVIATIONS

- < Less than; when appearing in the result column, indicates analyte not detected at or above the Reporting Limit.
- % Percent; To convert ppm to %, divide result by 10,000. To convert % to ppm, multiply the result by 10,000.
- *
- Indicates the Reporting Limit is elevated due to insufficient sample volume.
- mg/L Part per million; Concentration in units of milligrams of analyte per Liter of aqueous sample.
- ug/L Part per billion; Concentration in units of micrograms of analyte per Liter of aqueous sample.
- mg/kg Part per million; Concentration in units of milligrams of analyte per kilogram of non-aqueous sample.
- ug/kg Part per billion; Concentration in units of micrograms of analyte per kilogram of non-aqueous sample.
- a Indicates the sample concentration was quantitated using a diesel fuel standard.
- b Indicates the analyte of interest was also found in the method blank.
- c Sample resembles unknown Hydrocarbon.
- dw When indicated, the result is reported on a dry weight basis. The contribution of the moisture content in the sample has been subtracted when calculating the concentration.
- d1 Indicates the analyte has elevated Reporting Limit due to high concentration.
- d2 Indicates the analyte has elevated Reporting Limit due to matrix.
- e Indicates the reported concentration is estimated.
- g Indicates the sample concentration was quantitated using a gasoline standard.
- h Indicates the sample was analyzed past recommended holding time.
- i Insufficient spike concentration due to high analyte concentration in the sample.
- j Indicates the reported concentration is below the Reporting Limit.
- k Indicates the sample concentration was quantitated using a kerosene standard.
- l Indicates an MS/MSD was not analyzed due to insufficient sample. An LCS / LCS Duplicate provided for precision.
- m Indicates the sample concentration was quantitated using a mineral spirits standard.
- o Indicates the sample concentration was quantitated using a motor oil standard.
- p Indicates the sample was post spiked due to sample matrix.
- q Indicates MS/MSD exceeded control limits. The associated sample may exhibit similar matrix bias. All other quality control indicators are in control.
- r Indicates the sample was received past recommended holding time.
- u Indicates the sample was received improperly preserved and/or improperly contained.

TestAmerica, Inc. Indianapolis Division
6964 Hillisdale Ct., Indianapolis, IN 46250
Phone: (317) 842-4261

FAX: (317) 842-4286

TO: Mr. Richard Tyler
COMPANY: MILBANK MANUFACTURING INC

FROM: Josh Dutton
COMPANY: Indianapolis Division
PHONE: (317) 842-4261

SENT ON: Mon Oct 30 08:50:12 2000

NUMBER OF PAGES (INCLUDING COVER): 4

COMMENTS:

PLEASE CALL NUMBER ABOVE IF FAX TRANSMISSION IS INCOMPLETE.

This material is intended only for the use of the individual or entity to whom it is addressed, and may contain information that is privileged and confidential. If you are not the intended recipient, or the employee or agent responsible for delivering this material to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by telephone at the following toll free number 1-800-485-0204.

MIL0005528

DATE: OCTOBER 12TH, 2000

MILBANK MANUFACTURING COMPANY

PLEASE DUE THE MONTHLY TESTING FOR 10/12/00

TIME	METER READING	INITIALS
7:30	83400	SLH
8:00	83640	SLH
8:30	83880	SLH
9:00	84090	SLH
9:30	84320	SLH
10:00	84520	SLH
10:30	84730	SLH
11:00	84960	SLH
11:30	85100	SLH
12:00	85320	SLH
12:30	85550	SLH
1:00	85760	SLH
1:30	85970	SLH
2:00	86170	SLH
2:30	86400	SLH
3:00	86620	SLH
3:30	86770	SLH

Please test for the following highlighted
Due Monthly testing

10-12-00

Page 3 of 19

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: [1]

Discharge Limitations

Monitoring Requirements

<u>Regulated Parameter</u>	<u>Maximum for Any one Day mg/L</u>	<u>Monitoring Frequency</u>	<u>Sample Type</u>
Cadmium[5]	.02	Semi-Annual	Composite[2]
Total Chromium[5]	2.0	Semi-Annual	Composite[2]
Copper[5]	0.60	Semi-Annual	Composite[2]
Cyanide	0.50	Semi-Annual	Grab
Lead[5]	0.10	Semi-Annual	Composite[2]
Nickel[5]	0.80	Semi-Annual	Composite[2]
Silver[5]	0.24	Semi-Annual	Composite[2]
Zinc[5]	1.25	1 X Week	Composite[2]
Oil and Grease[6]	100	Semi-Annual	Grab
TPH[6]	(Monitor and report)	Semi-Annual	Grab
pH	6-10	Daily	Grab
CBOD [4]	(Monitor and report)	1 X Month	Composite[2]
Ammonia [4]	(Monitor and report)	1 X Month	Composite[2]
COD [4]	(Monitor and report)	1 X Month	Composite[2]
TSS [4]	(Monitor and report)	1 X Month	Composite[2]
Flow	N/A	Daily [3]	
TTO	2.13	Semi-Annual	Grab
Phenol	0.50	Semi-Annual	Grab
Molybdenum[5]	(Monitor and report)	1 X Month	Composite[2]

MIL0005530

DAILY: EVERY DAY SYSTEM RUNS

1X WEEK: 1 DAY OF WEEK COMPOSITE IS TAKEN (USUALLY THURSDAY)

1X MONTH: TO BE TAKEN FIRST WEEK COMPOSITE IS TAKEN FOR THAT MONTH

SEMI-ANNUAL: TO BE TAKEN FIRST WEEK IN JUNE AND FIRST WEEK IN DECEMBER

PART I

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Beginning the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge process wastewater, through discharge point # 2. Discharge through discharge point # 2 shall be limited and monitored by the permittee as specified below: (1)

Discharge Limitations

Monitoring Requirements

	Regulated Parameter	Maximum for Any one Day mg/L	RESULT	DATE TAKEN	Monitoring Frequency	Sample Type
Cd	Cadmium[5]	.02			Semi-Annual	Composite[2]
Cr	Total Chromium[5]	2.0			Semi-Annual	Composite[2]
Cu	Copper[5]	0.60			Semi-Annual	Composite[2]
Ca	Cyanide	0.50			Semi-Annual	Grab
Pb	Lead[5]	0.10			Semi-Annual	Composite[2]
Ni	Nickel[5]	0.80			Semi-Annual	Composite[2]
Ag	Silver[5]	0.24			Semi-Annual	Composite[2]
Zn	Zinc[5]	1.25	0.053	10-12-00	1 X Week	Composite[2]
FOG	Oil and Grease[6]	100			Semi-Annual	Grab
OIL + GREASE HYDROCARBONS	TPH[6]	(Monitor and report)			Semi-Annual	Grab
	pH	6-10			Daily	Grab
	CBOD [4]	(Monitor and report)	>10	10-12-00	1 X Month	Composite[2]
Nh3	Ammonia [4]	(Monitor and report)	<0.30	10-12-00	1 X Month	Composite[2]
	CO2 [4]	(Monitor and report)	700	10-12-00	1 X Month	Composite[2]
	TSS [4]	(Monitor and report)	96	10-12-00	1 X Month	Composite[2]
	Flow	N/A			Daily [3]	
*	TTO	2.13			Semi Annual	Grab
	Phenol	0.50			Semi-Annual	Grab
Mo	Molybdenum[5]	(Monitor and report)	0.028	10-12-00	1 X Month	Composite[2]

SEND TTO CERTIFICATION STATEMENT IN LIEU OF MONITORING ALONG WITH 40 CFR CATEGORICAL STATEMENT. MUST BE SENT EVERY JUNE AND DECEMBER (SEMI-ANNUAL)

MIL0005531